



Residential Natural Gas Meter Request Form

Customer Name: _____ Account #: _____ - _____ - _____

Service Address: _____

THE FOLLOWING ITEMS MUST BE COMPLETED BY THE PLUMBER/INSTALLER PRIOR TO SCHEDULING A GAS METER APPOINTMENT:

- _____ Are you connected to the meter bar?
- _____ Are water and electric active to the building and appliances?
- _____ Is the customer piping shutoff valve installed?
- _____ Is there a stainless steel flue gas liner Installed?
If not, attach Level 2 Chimney Inspection.

Note the BTU load/venting option for the appliances that will be onsite at the time of appointment:

Furnace	_____ BTU	→	Direct Vent	<input type="checkbox"/>	Chimney	<input type="checkbox"/>
Boiler	_____ BTU	→	Direct Vent	<input type="checkbox"/>	Chimney	<input type="checkbox"/>
Water Heater	_____ BTU	→	Direct Vent	<input type="checkbox"/>	Chimney	<input type="checkbox"/>
Dryer	_____ BTU		Fireplace	_____ BTU	Pool Heater	_____ BTU
Range	_____ BTU		Other	_____ BTU	Generator	_____ BTU

- Aluminum chimney liners are NOT permitted.
- Customer piping must be sleeved with a non-corrosive material when going through a masonry foundation and must be a minimum of 1" when installing appliances greater than 50k BTU. 1" black iron piping is required within 18" of the appliance along with an individual appliance shut off valve. When installing appliances less than 50k BTU, 3/4" black iron piping is adequate within 18" of the appliance. CSST (Corrugated Stainless Steel Tubing) piping must be installed by CSST certified contractor and bonded to the neutral in the electric panel.
- All existing and newly installed appliances must meet the current National Fuel Gas Code (NFGC) and NYS Fuel Gas Code, including safety devices (spill switches and low water cutoffs).

Refer to Central Hudson's "Redbook" for all specifications

https://www.cenhud.com/static_files/cenhud/assets/pdf/gas-specs-redbook.pdf

Please sign below and return with the pressure test. All the above requirements must be met in order to set and unlock a gas meter. You may also refer to Central Hudson's "Redbook" describing the above requirements. In activating the service, an initial inspection by Central Hudson personnel will be done at no charge. **If the piping system or appliance installation fails to meet our requirements, a fee may be applied for each subsequent re-inspection conducted, with payment to be made prior to re-inspection.**

Contractor Acknowledgement

Customer Acknowledgement

Sign: _____

Sign: _____

Print: _____

Print: _____

Date: _____

Date: _____